

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1501:122 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: *Edwards Signaling, 90 Fieldstone Court, Cheshire, CT 06410
Contact: David Mazur (203) 699-3000 Fax (203) 699-3100

DESIGN: Models 106DEX, followed by P, B or C; followed STC-FJ adaptabeacon strobe light. The devices employ the use of a pendant, ceiling or wall bracket mount connected to an enclosure of explosion-proof and dust-ignition-proof construction. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 20-30 VDC
Candela: 75cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as strobe light for use in Class I, Groups C and D; Class I, Division 2, Groups A, B, C and D; Class II, Groups E, F and G; Class III hazardous locations and intended for use with separately listed compatible fire alarm control units. For indoor use only, Type 3R and 4X.

*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager